



HFC-227_{EA} INSTRUCTIONAL SIGNS

APPLICATION

Instructional signs must be supplied in order to provide a system in which the function of all devices is easy to understand. Fike offers several different standard signs that comply with NFPA and other industry requirements. All signs are durable plastic and backed with a strong adhesive for easy installation. Signs are typically installed at all entrances (CAUTION - Room Protected By HFC-227_{ea}) and near any device for which the extra explanation is helpful. Custom signs are available upon special request.

System "Release" Sign/Manual Release Station 02-10137

The purpose of the System "Release" Sign is to identify the manual release station as the place where the HFC-227_{ea} System can be manually discharged. It also minimizes the possibility of the manual station being mistaken for a fire alarm device. The sign is 4" x 2.25" x 1/16" (102 x 57 x 1.6mm) and is constructed of red plastic with white lettering. The System "Release" Sign should normally be located under each HFC-227_{ea} manual release station for quick positive identification.

Upon Device Activation "Do Not Enter" Sign 02-10138

The purpose of the System Discharge Sign is to explain the presence of an alarm in the event of a HFC-227_{ea} System discharge. The sign is 9" x 6" x 1/16" (229 x 152 x 1.6mm) and is constructed of white plastic with black lettering. The System Discharge Sign is located next to or under an audible or visual alarm outside of the protected space entrance(s). This sign, together with the alarm device(s) will alert personnel when HFC-227_{ea} agent has discharged and allow them to take appropriate actions.

Caution "Do Not Enter" Sign 02-10139


The purpose of the Caution Sign is to alert personnel that the room is protected by an HFC-227_{ea} System and that all doors should be kept closed in the event of fire. The sign is 10" x 13" x 1/16" (254 x 330 x 1.6mm) and constructed of yellow plastic with black lettering. The Caution Sign should normally be located on the entrance door(s) leading into any room where HFC-227_{ea} protection is being provided.

Upon Device Activation "Exit" Sign 02-10105

The purpose of the System Discharge Sign is to explain the presence of an alarm in the event of an HFC-227_{ea} System discharge. The sign is 9" x 6" x 1/16" (229 x 152 x 1.6mm) and is constructed of white plastic with black lettering. The System Discharge Sign is located next to or under an audible or visual alarm inside of the protected space. This sign, together with the alarm device, will alert personnel when HFC-227_{ea} agent has been discharged and allow them to take appropriate action.

System Abort "Push and Hold" Sign 02-10106

The purpose of this System Abort Sign is to identify the presence of the HFC-227_{ea} System Abort Station. The sign is 4" x 2.25" x 1/16" (102 x 57 x 1.6mm) and is constructed of red plastic with white lettering. The System Abort Station is designed to provide a manual means by which the HFC-227_{ea} system actuation circuit may be interrupted. The System Abort Sign should be located next to each HFC-227_{ea} Abort Station for quick positive identification.



Form No. C.1.10.01-3

APPLICATION (Cont.)

System "Main/Reserve" Sign 02-10107

The purpose of Main/Reserve Sign is to identify the presence of the HFC-227ea Main/Reserve Switch Station. The sign is 4" x 2.25" x 1/16" (102 x 57 x 1.6mm) and is constructed of red plastic with white lettering. The Main/Reserve Sign should be located under the Main/Reserve Switch for positive identification. A Main/Reserve Switch is used with systems that incorporate main and reserve (back up) HFC-227ea Agent storage.



Release Pending Sign 02-10268

The purpose of the Release Pending Sign is to explain the presence of an alarm in the event of an impending HFC-227ea System discharge. The sign is 7" x 4.25" x 1/16" (178 x 108 x 1.6mm) and is constructed of red plastic with white lettering. The Release Pending Sign is located next to an audible or visual alarm inside of the protected space. This sign, together with the alarm device, will alert personnel of a forthcoming HFC-227ea Agent discharge and allow them to take appropriate action.

